

Equipment for Ammonia Mechanical room Cleveland Ohio

Ammonia Compressors

Description	Manufacturer	Model	Serial	Comments
Compressor 1	Velter	A11L456XLD	63085	1990
Compressor 2	Velter	A11L456XLD	63086X	1990
Compressor 3	Velter	A11L456XLD	63084	1990
Compressor 4	Velter	A11L456XLD	63087X	1990
Compressor 5	Velter	A11L456XLD	65021	1995
Compressor 6	Velter	A11L456XLD	65045	1995
Compressor 7	Velter	A11K4512XLD	65046	1995
Compressor 8	Velter	A11B458XLD	48061	1995
Compressor 9	Velter	A11B458XLD	48060	1995

Cooling Tower Indoor Sump 1995

Pump 1	B&G	4BC 8 3/4 BF	???3098	1995
Pump 2	B&G	4BC 8 3/4 BF	1582293	1995
Pump 3	B&G	4BC 8 3/4 BF	1582291	1995 off line needs repairs

Indoor sump floats N/G, all gauges need to be replaced

Liquid Pumps for +13 Vessel 1990

Pump 1	Cornell	2CB-5-4	89007	1995 need replacement
Pump 2	Cornell	2CB-5-4	89008	1995 need replacement

Liquid Pumps for -25 Vessel 1995

Pump 1	Cornell	2CB-5-4	88758	1995 need replacement
Pump 2	Cornell	2CB-5-4	88745	1995 need replacement

Towers on Roof Jack Tracey to provide all data was not visible on equipment said he had info somewhere

Tower 1	Imeco			1990 in need of repairs
Tower 2	Evapco			1995

Emergency Generator outside of this building is emergency lighting only for all freezers and coolers. Unit was locked and Jack did not have key is going to forward all information

The Computer which controls the Ammonia system is in need of upgrading.